

**EXLTUBE®**

1000 BURLINGTON STREET, NORTH KANSAS CITY, MO 64116 1-816-474-5210 TOLL FREE 1-800-892-TUBE

**STEEL VENTURES, LLC dba EXLTUBE****Certified Test Report**

Customer: SPS - Tulsa 1020 Fort Gibson Road Catoosa OK 74015-3033	Size: 03.00X04.00	Customer Order No: 4500540183	Customer Part No: 6640030018840
	Gauge: 3/16	Delivery No: 85311718	Length: 40 FT
	Date: 11/11/2022	Load No: 7247674	
Specification: ASTM A500-21 Gr.B/C			

Heat No	Yield KSI	Tensile KSI	Elongation % 2 Inch
10016C	55.9	70.5	31.50

Heat No	C	MN	P	S	SI	CU	NI	CR	MO	V
10016C	0.1900	0.7500	0.0080	0.0060	0.0090	0.0200	0.0100	0.0300	0.0000	0.0000

This material was melted & manufactured in the U.S.A. This material meets the Buy America requirement of 23 CFR 635.410.  
Coil Producing Mill: UNITED STATES STEEL, Granite City, IL

We hereby certify that all test results shown in this report are correct as contained in the records of our company. All testing and manufacturing is in accordance to A.S.T.M. parameters encompassed within the scope of the specifications denoted in the specification and grade tiles above. This product was manufactured in accordance with your purchase order requirements.

This material has not come into direct contact with mercury, any of its compounds, or any mercury bearing devices during our manufacturing process, testing, or inspections.

This material is in compliance with EN 10204 Section 4.1 Inspection Certificate Type 3.1

Tensile test completed using test specimen with 3/4" reduced area.

STEEL VENTURES, LLC dba EXLTUBE

Jonathan Wolfe  
Quality Assurance Manager