

Atlas Tube Alabama
 171 Cleage Dr
 Birmingham Alabama USA
 35217

Tel:
 Fax:



REF./L: 81154200
 Date: 05/17/2023
 Customer: 1592

MATERIAL TEST REPORT

USA
 USA

Material: 2.0x2.0x250x20"0(6x6). **Material No:** 0200202502000-B **Made in:** USA
Sales Order: 1914075 **Purchase Order:** P0241573-01 **Melted and Poured in:** USA
Heat No C Mn P S Si Al Cu Cb Mo Ni Cr V Ti B N Ca **Cust Material#:** 982024310
 NN2390 0.200 0.380 0.007 0.002 0.025 0.030 0.130 0.000 0.010 0.040 0.050 0.002 0.000 0.0080 0.0030
Bundle No PCs Yield Tensile Eln.2in **Certification**
 MC00208934 36 068162 Psi 079111 Psi 25.5% ASTM A500-21 GRADE B&C
Heat MILL Location Method Recycled Content Post Consumer Pre-Consumer (Post Industrial) % Harvested Within Miles of Location
 NN2390 NUCOR Decatur,AL EAF 53.70% 23.80% 29.90% 86% 500
Material Note:
Sales Or. Note:

Material: 2.0x2.0x250x20"0(6x6). **Material No:** 0200202502000-B **Made in:** USA
Sales Order: 1914085 **Purchase Order:** P0241573-01 **Melted and Poured in:** USA
Heat No C Mn P S Si Al Cu Cb Mo Ni Cr V Ti B N Ca **Cust Material#:** 982024310
 2304644 0.210 0.810 0.008 0.003 0.020 0.025 0.090 0.000 0.010 0.040 0.060 0.002 0.001 0.0060 0.0020
Bundle No PCs Yield Tensile Eln.2in **Certification**
 MC00207511 36 071019 Psi 077590 Psi 27.5% ASTM A500-21 GRADE B&C
Material Note:
Sales Or. Note:

Authorized by Quality Assurance *Jason Richard*
Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. Steel is purchased fully killed with a fine grain practice. This document is in compliance with the requirements of EN10204 type3.1

