

Atlas Tube Alabama
 171 Cleage Dr
 Birmingham Alabama USA
 35217
 Tel:
 Fax:



REF.B/L: 81124385
 Date: 11/29/2022
 Customer: 1592

MATERIAL TEST REPORT

Sold To

Superior Supply and Steel
 PO Box 2388
 SULPHUR LA 70664
 USA

Shipped To

Superior Supply and Steel
 318 North Cities Service Hwy
 SULPHUR LA 70663
 USA

Material: 3.0x3.0x188x20"0"(5x5).

Material No: 0300301882000-B

Made in: USA

Sales Order: 1844858

Purchase Order: P0237042-11

Melted and Poured in: USA
Cust Material#: 982024520

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
SM5829	0.200	0.400	0.008	0.001	0.029	0.032	0.120	0.000	0.010	0.040	0.050	0.002	0.001	0.000	0.0080	0.0020
Bundle No	PCs		Yield	Tensile	Eln.2in	Certification										
MA00143776	25		063035 Psi	067864 Psi	27.7 %	ASTM A500-21 GRADE B&C										
Heat	MILL		Mill Location		Method	Recycled Content	Post Consumer	Pre-Consumer	(Post Industrial)	% Harvested	Within Miles of Location					
SM5829	NUCOR		Decatur,AL		EAF	53.70%	23.80%	29.90%	86%	500						

Material Note:

Sales Or. Note:

Material: 3.0x3.0x188x24"0"(5x5).

Material No: 0300301882400-B

Made in: USA

Sales Order: 1849115

Purchase Order: P0237042-11

Melted and Poured in: USA
Cust Material#: 982024522

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
NM5705	0.190	0.370	0.006	0.003	0.028	0.031	0.120	0.000	0.020	0.040	0.050	0.001	0.002	0.000	0.0060	0.0020
Bundle No	PCs		Yield	Tensile	Eln.2in	Certification										
MA00143738	25		060794 Psi	064263 Psi	27.6 %	ASTM A500-21 GRADE B&C										
Heat	MILL		Mill Location		Method	Recycled Content	Post Consumer	Pre-Consumer	(Post Industrial)	% Harvested	Within Miles of Location					
NM5705	NUCOR		Decatur,AL		EAF	53.70%	23.80%	29.90%	86%	500						

Material Note:

Sales Or. Note:

Authorized by Quality Assurance *Jason Richard*
Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. This document is in compliance with the requirements of EN 10204 type 3.1

