



1000 N Burlington Street
North Kansas
City,MO,US,64116

Sold To:
Superior Supply and Steel
Sulphur ,LA,70664
US

Ship To:
Superior Supply and Steel
318 North Cities Service Hwy
Sulphur ,LA,70663
US

REF/BOL:81277360

| | | |
|--------------------------|--------------------|---------------------------------|
| Heat #: R87062C24 | Made In: US | Melted and Poured In: US |
|--------------------------|--------------------|---------------------------------|

| C | Mn | P | S | SI | AI | CU | CB | MO | NI | CR | V | TI | B | N |
|-----|-----|-------|-------|-------|-------|------|-----|-----|------|------|-----|-------|--------|-------|
| 0.2 | 0.8 | 0.008 | 0.005 | 0.021 | 0.049 | 0.04 | 0.0 | 0.0 | 0.01 | 0.04 | 0.0 | 0.002 | 0.0001 | 0.005 |

| | |
|-----------------------------|--------------------------------------|
| Material Group# : 040040375 | Certification:ASTM A500-23 GRADE B&C |
|-----------------------------|--------------------------------------|

| Yield | Tensile | Eln.2ln | CE |
|------------|------------|---------|------|
| 064312 Psi | 074476 Psi | 31.5 % | 0.35 |

| Mill | Mill Location | Method | Recycled Content | Post Consumer | Pre-Consumer (Post Industrial) | % Harvested | Within Miles of Location |
|---------|-----------------|--------|------------------|---------------|--------------------------------|-------------|--------------------------|
| USSTEEL | GRANITE CITY,IL | BOF | 36.90% | 19.80% | 14.40% | 100.00% | 500.00 |

| Material | Customer Item | Customer Note |
|-------------------------|---------------|---------------|
| 4.0x4.0x375x20'0"(5x4). | | |

| Bundle No | Pcs | Purchase Order | Sales Order | Sales Order Note |
|------------|-----|----------------|-------------|------------------|
| Z200073661 | 20 | P0254998-01 | 0002156130 | |
| Z200073662 | 20 | P0254998-01 | 0002156130 | |
| Z200073663 | 20 | P0254998-01 | 0002156130 | |

Authorized by Quality Assurance: *Jason Richard* Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. This document is in compliance with the requirements of EN 10204 type 3.1

