



CMC STEEL TEXAS
1 STEEL MILL DRIVE
SEGUN TX 78155-7510

CERTIFIED MILL TEST REPORT
For additional copies call
830-372-8771

We hereby certify that the test results presented here
are accurate and conform to the reported grade specification

1SERIES-BPS

Quality Assurance Manager

Rolando A Davila

HEAT NO.: 3093181

SECTION: FLAT 1/4X6 20'0" A36/52955
GRADE: ASTM A36-19/A529-14 Gr 55
ROLL DATE: 12/08/2019
MELT DATE: 12/06/2019
Cert. No.: 82923701 / 093181A088

S Superior Supply & Steel Co
O 318 N Cities Service Hwy
L Sulphur LA
D US 70663-5424
T 3376252300
O 3376258509

S Superior Steel
H 217 Darnall Rd
I New Iberia LA
P US 70560-0781
T 8002529017
O

Delivery#: 82923701
BOL#: 73327625
CUST PO#: P0212260-08
CUST P/N:
DLVRY LBS / HEAT: 4896.000 LB
DLVRY PCS / HEAT: 48 EA

Characteristic	Value	Characteristic	Value	Characteristic	Value
C	0.14%	Elongation test 1	33%	<p>The Following is true of the material represented by this MTR:</p> <p><i>*Material is fully killed</i></p> <p><i>*100% melted and rolled in the USA</i></p> <p><i>*EN10204:2004 3.1 compliant</i></p> <p><i>*Contains no weld repair</i></p> <p><i>*Contains no Mercury contamination</i></p> <p><i>*Manufactured in accordance with the latest version of the plant quality manual</i></p> <p><i>*Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 661</i></p> <p><i>*Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov</i></p>	
Mn	0.68%	Elongation Gage Lgth test 1	8IN		
P	0.013%	Yield to tensile ratio test1	0.78		
S	0.022%	Yield Strength test 2	59.5ksi		
Si	0.20%	Tensile Strength test 2	76.0ksi		
Cu	0.34%	Elongation test 2	31%		
Cr	0.14%	Elongation Gage Lgth test 2	8IN		
Ni	0.09%	Yield to tensile ratio test2	0.78		
Mo	0.034%				
V	0.000%				
Cb	0.017%				
Sn	0.009%				
B	0.0000%				
Ti	0.001%				
N	0.0094%				
Carbon Eq A6	0.32%				
Carbon Eq A529	0.35%				
Yield Strength test 1	59.4ksi				
Tensile Strength test 1	76.3ksi				

REMARKS : ALSO MEETS ASTM GRADE A36, A529-50, A529-55, A572-50, A572-55, A709-36, A709-50, AASHTO M270-36, M270-50, CSA G40.21-04 44W, 50W, 55W