

Atlas Tube Alabama  
171 Cleage Dr  
Birmingham Alabama USA  
35217  
Tel:  
Fax:



REF.B/L: 81084148  
Date: 04/26/2022  
Customer: 1592

**Sold To**

Superior Supply and Steel  
PO Box 2388  
SULPHUR LA 70664  
USA

**Shipped To**

Superior Supply and Steel  
318 North Cities Service Hwy  
SULPHUR LA 70663  
USA

**MATERIAL TEST REPORT**

**Material:** 2.0x2.0x120x20"0"(10x5).

**Sales Order:** 1778303

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
SM1154	0.190	0.390	0.008	0.004	0.017	0.034	0.120	0.000	0.010	0.040	0.050	0.003	0.001	0.000	0.0060	0.0030

**Bundle No** PCS 50  
MC00173058  
**Yield** 062415 Psi  
**Tensile** 066960 Psi  
**EIn.2in** 29.8 %  
**Recycled Content** 53.70%  
**Method** EAF  
**Post Consumer** 23.80%  
**Pre-Consumer** 29.90%  
**CE: 0.28**

**Heat** MILL  
SM1154 NUCOR  
**Yield Location** Decatur,AL  
**Recycled Content** 53.70%  
**Post Consumer** 23.80%  
**Pre-Consumer** 29.90%  
**CE: 0.28**

**Material Note:**  
**Sales Or. Note:**

**Material:** 2.0x2.0x120x24"0"(10x5).

**Sales Order:** 1767326

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
SM1678	0.190	0.390	0.008	0.006	0.015	0.030	0.160	0.000	0.020	0.040	0.050	0.001	0.001	0.000	0.0070	0.0020

**Bundle No** PCS 50  
MC00175038  
**Yield** 059139 Psi  
**Tensile** 062698 Psi  
**EIn.2in** 26.4 %  
**Recycled Content** 53.70%  
**Method** EAF  
**Post Consumer** 23.80%  
**Pre-Consumer** 29.90%  
**CE: 0.29**

**Heat** MILL  
SM1678 NUCOR  
**Yield Location** Decatur,AL  
**Recycled Content** 53.70%  
**Post Consumer** 23.80%  
**Pre-Consumer** 29.90%  
**CE: 0.29**

**Material Note:**  
**Sales Or. Note:**

Authorized by Quality Assurance *Jason Richard*  
**Jason Richard**

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. This document is in compliance with the requirements of EN 10204 type 3.1

