

CMC STEEL TENNESSEE 1919 Tennessee Avenue Knoxville TN 37921-2686

## CERTIFIED MILL TEST REPORT For additional copies call 800-227-6489

We hereby certify that the test results presented here are accurate and conform to the reported grade specification

Jim Hall

## Quality Assurance Manager

HEAT NO.:7038588 SECTION: REBAR 10MM (#3) 20'0" 420/60	၁ ဖ	Superior Supply & Steel Co	S Superior Supply & Steel Co	
B270		318 N CITIES SERVICE HWY	1 318 N CITIES SERVICE HWY	-
GRADE: ASTM A615-22 Gr 420/60		SULPHUR LA	P SUI PHUR I A	CHIST D/M:
ROLL DATE: 11/27/2023		US 70663-5424		DIVENTED A DEAT - 2020 000 LB
MELT DATE: 11/18/2023	<b>-</b> i	3376252300	T 3376252300	DI VEV DOS / HEAT. 2030:000 LB
Cert. No.: 85649836 / 038588L991		3376258509		DEVNY PCS / HEAT: 2/0 EA
Characteristic Value		Characteristic V	Value	Characteristic Value
C 0.44%		Bend Test 1	t 1 Passed	
Mn 0.88%		Rebar Deformation Avg. Spaci		
P 0.009%		Rebar Deformation Avg. Heigh		
S 0.049%		Rebar Deformation Max. Gap		
Si 0.22%				
Cu 0.34%				
Cr 0.11%				
Ni 0.09%				
Mo 0.031%				The Following is true of the material represented by this MTR:
V 0.001%				*Material is fully killed and is Hot Rolled Steel
Sn 0.004%				*100% melted, rolled, and manufactured in the USA
				*EN10204:2004 3.1 compliant
Yield Strength test 1 71.0ksi				*Contains no weld repair
Yield Strength test 1 (metri 490MPa				*Contains no Mercury contamination
Tensile Strength test 1 108.5ksi				*Manufactured in accordance with the latest version
Tensile Strength 1 (metric) 748MPa				of the plant quality manual
Elongation test 1 14%				*Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 661
Elongation Gage Lgth test 1 8IN				*Warning: This product can expose you to chemicals which are
Tensile to Yield ratio test1 1.53				barrier at the Octate of Octate of the Control of t
Elongation Gage Lgth 1(metri 200mm				Known to the State of California to cause cancer, birth defects
				or other reproductive harm. For more information go