NUCOR

Mill Certification

11/08/2022

MTR#:1178555-7 Lot #:120204597660 W CEMETERY ROAD PLYMOUTH, UT 84330 US 800 453-2886 Fax: 435 458-2309

Sold To:

Ship To:

Customer PO	4500536056	Sales Order #	11050370 - 2.1
Product Group	Hot Roll - Merchant Bar Quality	Product #	3006859
Grade	A36/A529 Gr 50, CSA 44W/50W	Lot #	120204597660
Size	2" x 1.5" x 0.25"	Heat #	1202045976
BOL #	BOL-1277976	Load #	1178555
Description	Hot Roll - Merchant Bar Quality Unequal Angle 2" x 1 1/2" x 1/4" A36/A529 Gr 50, CSA 44W/50W 20' 0" [240"] 2001-6000 lbs	Customer Part #	50200116820
Production Date	10/19/2022	Qty Shipped LBS	3989
Product Country Of Origin	United States	Qty Shipped EA	72
Original Item Description		Original Item Number	

I hereby certify that the material described herein has been manufactured in accordance with the specifications and standards listed above and that it satisfies those requirements.
Melt Country of Origin : United States
Melting Date: 10/11/2022

Country of Origin : United States							Melting Date: 10/11/2022				2
<u>C (%)</u>	<u>Mn (%)</u>	<u>P (%)</u>	<u>S (%)</u>	<u>Si (%)</u>	<u>Ni (%)</u>	<u>Cr (%)</u>	<u>Mo (%)</u>	<u>Cu (%)</u>	<u>V (%)</u>	<u>Nb (%)</u>	
0.18	0.72	0.013	0.041	0.20	0.09	0.17	0.02	0.25	0.002	0.002	

Tensile testing

	Yield (PSI)	Tensile (PSI)	Elongation in 8" (%)
(1)	50000	74000	31.0
(2)	50500	74100	30.0

Comments:

ASTM A36/A36M-19, ASTM A529/A529M-19 GR50, CSA G40.21-13(R2018) 44W(300W)/50W(350W), ASTM A709/A709M-18 GR36, AASHTO M 270/M 270M-19 GR36, ASME SA36/SA36M-17

Nucor Steel Utah is in compliance with and certified to: ISO 9001:2015, ISO 14001:2015, ABS Quality Assurance Program & AASHTO's NTPEP Reinforcing Steel and Wire (REBAR) Technical Committee Work Plan.

All manufacturing processes of the steel materials in this product, including melting, casting and hot rolling have occurred within the United States. Mercury not intentionally added at any point during manufacture or testing of this product. This material is free of HG contamination and is ROHS compliant. No weld repair was performed.

Material meets the requirements of the purchase order and have been produced under the Nucor Steel Utah Quality Manual. Mill Certificate complies with DIN EN 10204 – 3.1.

Material and Mill Certification are in full compliance with the American Iron and Steel requirement as mandated in EPA's State Revolving Fund Programs and complies with the Buy America Act, and (FTA) Buy America Requirements (49 C.F.R. part 661 & 23 CFR part 635.410).).