



CMC STEEL TEXAS  
1 STEEL MILL DRIVE  
SEGUIN TX 78155-7510

CERTIFIED MILL TEST REPORT  
For additional copies call  
800-227-6489

We hereby certify that the test results presented here  
are accurate and conform to the reported grade specification

1SERIES-BPS<sup>®</sup>

Rolando A Davila  
Quality Assurance Manager

HEAT NO.: 3118965	S	Superior Supply & Steel Co	S	Superior Supply & Steel Co	Delivery#: 85270293
SECTION: ANG 2 1/2 X 2 1/2x1/4 20'0"	O	318 N Cities Service Hwy	H	318 N Cities Service Hwy	BOL#: 75136359
A36/52950	L	Sulphur LA	I	Sulphur LA	CUST PO#: P0238257-11
GRADE: ASTM A36-19/A529-14 Gr 50	D	US 70663-5424	P	US 70663-5424	CUST P/N:
ROLL DATE: 11/11/2022	T	3376252300	T	3376252300	DLVRY LBS / HEAT: 4674,000 LB
MELT DATE: 10/08/2022	O	3376258509	O	3376258509	DLVRY PCS / HEAT: 57 EA
Cert. No.: 85270293 / 118965A397					

Characteristic	Value	Characteristic	Value	Characteristic	Value
C	0.09%	Yield to tensile ratio test1	0.76	The following is true of the material represented by this MTR: *Material is fully killed and is Hot Rolled Steel * 100% melted, rolled, and manufactured in the USA *EN10204-2004 3.1 compliant *Contains no weld repair *Contains no Mercury contamination *Manufactured in accordance with the latest version of the plant quality manual *Meets the "Buy America" requirements of 23 CFR635, 410, 49 CFR 667 *Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov	
Mn	1.11%	Yield Strength test 2	56.7ksi		
P	0.012%	Tensile Strength test 2	75.2ksi		
S	0.031%	Elongation test 2	30%		
Si	0.24%	Elongation Gage Lgth test 2	8IN		
Cu	0.34%	Yield to tensile ratio test2	0.75		
Cr	0.07%				
Ni	0.10%				
Mo	0.024%				
V	0.000%				
Carbon Eq A529	0.37%				
Carbon Eq A992	0.32%				
Yield Strength test 1	57.4ksi				
Tensile Strength test 1	75.2ksi				
Elongation test 1	34%				
Elongation Gage Lgth test 1	8IN				

REMARKS : ALSO MEETS ASTM GRADE A36, A529-50, A572-50, A709-36, A709-50, A992, AASHTO M270-36, M270-50, CSA G40.21 04 44W, 50W