



CMC STEEL ALABAMA
101 S 50TH STREET
BIRMINGHAM AL 35212-3525

CERTIFIED MILL TEST REPORT

For additional copies call
800-637-3227

We hereby certify that the test results presented here
are accurate and conform to the reported grade specification

Marcus W. McCluney - CMC Steel AL
Quality Assurance Manager

1SERIES-BPS®

HEAT NO.:1082615 SECTION: ANG 4 X 4x3/8 20'0" A36/52950 GRADE: ASTM A36-19/A529-14 Gr 50 ROLL DATE: 10/07/2022 MELT DATE: 09/28/2022 Cert. No.: 85192293 / 082615B175	S O L D T O	S H I P T O	Delivery#: 85192293 BOL#: 75015451 CUST PO#: 4500535325 CUST P/N: 504004001220 DLVRY LBS / HEAT: 9800.000 LB DLVRY PCS / HEAT: 50 EA
--	--------------------------------	--------------------------------	---

Characteristic	Value	Characteristic	Value	Characteristic	Value
C	0.14%	Elongation Gage Lgth test 1	8IN	<p>The Following is true of the material represented by this MTR: <i>*Material is fully killed and is Hot Rolled Steel</i> <i>*100% melted, rolled, and manufactured in the USA</i> <i>*EN10204:2004 3.1 compliant</i> <i>*Contains no weld repair</i> <i>*Contains no Mercury contamination</i> <i>*Manufactured in accordance with the latest version of the plant quality manual</i> <i>*Meets the "Buy America" requirements of 23 CFR635.410, 49 CFR 661</i> <i>*Warning: This product can expose you to chemicals which are known to the State of California to cause cancer, birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov</i></p>	
Mn	0.68%	Yield to tensile ratio test1	0.73		
P	0.014%	Yield Strength test 2	54.3ksi		
S	0.035%	Tensile Strength test 2	74.8ksi		
Si	0.17%	Elongation test 2	25%		
Cu	0.50%	Elongation Gage Lgth test 2	8IN		
Cr	0.16%	Yield to tensile ratio test2	0.73		
Ni	0.12%				
Mo	0.038%				
V	0.004%				
Cb	0.010%				
Sn	0.014%				
B	0.0003%				
Ti	0.001%				
N	0.0092%				
Carbon Eq A6	0.34%				
Carbon Eq A529	0.37%				
Yield Strength test 1	54.8ksi				
Tensile Strength test 1	75.0ksi				
Elongation test 1	27%				

REMARKS : ALSO MEETS ASTM GRADE A36 REV 08, A572-50, A709-36, A709-50, A992, AASHTO GRADE M270-36, M270-50, CSA G40.21-04 GRADE 44W, 50W, ASME SA-36 2008A ADDEND A.