

Sold By:
NUCOR TUBULAR PRODUCTS INC.
DECATUR DIVISION
2000 INDEPENDENCE AVENUE N.W.
DECATUR, AL 35601
Tel: 256 306-6200
Fax: 256 340-7415

Purchase Order No: 4500543443
Sales Order No: DCR 160274 - 1
Bill of Lading No: DCR 115957 - 4
Invoice No:

Shipped: 1/10/2023
Invoiced:

CERTIFICATE of ANALYSIS and TESTS

Customer Part No:

Certificate No: DCR 908978

Test Date: 1/5/2023

TUBING A500 GRADE B(C)
10" X 4" X 3/16" X 40'

Total Pieces Total Weight Lbs
12 8,198

Bundle Tag	Mill	Heat	Specs	Y/T Ratio	Pieces	Weight Lbs
218078	40N	NM7289	YLD=61000/TEN=78300/ELG=35	0.7791	6	4,099
218087	40N	NM7289	YLD=61000/TEN=78300/ELG=35	0.7791	6	4,099

Mill #: 40N Heat #: NM7289 Carbon Eq: 0.2884 Heat Src Origin: MELTED AND MANUFACTURED IN THE USA

C	Mn	P	S	Si	Al	Cu	Cr	Mo	V	Ni	Nb	Sn
0.2000	0.4000	0.0070	0.0040	0.0250	0.0250	0.1300	0.0400	0.0100	0.0020	0.0400	0.0060	0.0040
N	Ti	Ca										
0.0063	0.0010	0.0011										

Certification:

I certify that the above results are a true and correct copy of records prepared and maintained by NUCOR TUBULAR PRODUCTS INC. Sworn this day, 1/5/2023.

THE SPECIFICATIONS LISTED BELOW REPRESENT THE CURRENT ISSUED DATES OF THESE STANDARDS. THIS DOES NOT INDICATE THAT THE MATERIAL ABOVE CONFORMS TO EACH OR ALL OF THE STANDARDS. WE CERTIFY THE MATERIAL ABOVE TO THE SPECIFICATION LISTED IN THE LINE DESCRIPTION.

CURRENT STANDARDS:
A252-19
A500/A500M-21
A513/A513M-21
ASTM A53/A53M-20| ASME SA-53/SA-53M-21
A847/A847M-14
A1085/A1085M-15
IN COMPLIANCE WITH EN 10204 SECTION 4.1
INSPECTION CERTIFICATE TYPE 3.1



Nora Oukajji
Metallurgist/Quality Supervisor