

Atlas Tube Arkansas
 6651 E Hwy 137
 Blytheville Arkansas USA
 72315
 Tel:
 Fax:



REF.B/L: 81137722
 Date: 02/17/2023
 Customer: 179

MATERIAL TEST REPORT

Sold To

Steel & Pipe Supply Company
 PO Box 1688
 MANHATTAN KS 66505
 USA

Shipped To

Steel & Pipe c/o Longview Whse
 4750 West Marshall Avenue
 LONGVIEW TX 75604
 USA

Material: 1.5x1.5x125x24'0"0(8x8). **Material No:** 150151252400 **Made in:** USA
Sales Order: 1878656 **Purchase Order:** C455006524 **Melted and Poured in:** USA
Cust Material#: 6511612024

Heat No	C	Mn	P	S	Si	Al	Cu	Cb	Mo	Ni	Cr	V	Ti	B	N	Ca
SM7610	0.200	0.380	0.003	0.003	0.024	0.025	0.120	0.000	0.010	0.030	0.030	0.003	0.001	0.0000	0.0060	0.0010

Bundle No	PCs	Yield	Tensile	EIn.2in	Certification	CE: 0.29		
MC00200239	64	067484 Psi	072382 Psi	27 %	ASTM A500-21 GRADE B&C			
Heat	MILL	Mill Location	Method	Recycled Content	Post Consumer	Pre-Consumer (Post Industrial)	% Harvested	Within Miles of Location
SM7610	NUCOR	Decatur,AL	EAF	53.70%	23.80%	29.90%	86%	500

Material Note:
Sales Or. Note:

Authorized by Quality Assurance: *Jason Richard*
Jason Richard

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. This document is in compliance with the requirements of EN 10204 type 3.1

