

Sold By:
NUCOR TUBULAR PRODUCTS INC.
DECATUR DIVISION
2000 INDEPENDENCE AVENUE N.W.
DECATUR, AL 35601
Tel: 256 306-6200
Fax: 256 340-7415

Purchase Order No: 4500557925
Sales Order No: DCR 172292 - 1
Bill of Lading No: DCR 123752 - 4
Invoice No:

Shipped: 8/25/2023
Invoiced:

4750 W. MARSHALL AVENUE
LONGVIEW, TX 75604

4750 W. MARSHALL AVENUE
LONGVIEW, TX 75604

CERTIFICATE of ANALYSIS and TESTS

Certificate No: DCR 51379

Customer Part No:

Test Date: 8/23/2023

TUBING A500 GRADE B(C)
8" SQ X 5/8" X 40'

Total Pieces Total Weight Lbs
4 9,491

Bundle Tag	Mill	Heat	Specs	Y/T Ratio	Pieces	Weight Lbs
261333	40N	NN4111	YLD=68900/TEN=81900/ELG=27.5	0.8413	4	9,491

Mill #: 40N Heat #: NN4111 Carbon Eq: 0.2996 Heat Src Origin: MELTED AND MANUFACTURED IN THE USA

C	Mn	P	S	Si	Al	Cu	Cr	Mo	V	Ni	Nb	Cb
0.2000	0.4300	0.0130	0.0010	0.0330	0.0280	0.1300	0.0700	0.0100	0.0030	0.0400	0.0060	0.0060
Sn	N	B	Ti	Ca								
0.0010	0.0050	0.0003	0.0030	0.0016								

Certification:

I certify that the above results are a true and correct copy of records prepared and maintained by NUCOR TUBULAR PRODUCTS INC. Sworn this day, 8/23/2023.

THE SPECIFICATIONS LISTED BELOW REPRESENT THE CURRENT ISSUED DATES OF THESE STANDARDS. THIS DOES NOT INDICATE THAT THE MATERIAL ABOVE CONFORMS TO EACH OR ALL OF THE STANDARDS. WE CERTIFY THE MATERIAL ABOVE TO THE SPECIFICATION LISTED IN THE LINE DESCRIPTION.

CURRENT STANDARDS:

A252-19
A500/A500M-21
A513/A513M-21
ASTM A53/A53M-20 | ASME SA-53/SA-53M-21
A847/A847M-14
A1085/A1085M-15
IN COMPLIANCE WITH EN 10204 SECTION 4.1
INSPECTION CERTIFICATE TYPE 3.1



Nora Oukajji
Metallurgist/Quality Supervisor