

CERTIFIED MATERIAL TEST REPORT



US-ML-MIDLOTHIAN
300 WARD ROAD
MIDLOTHIAN, TX 76065
USA

CUSTOMER SHIP TO		CUSTOMER BILL TO		GRADE A992/A572-50	SHAPE / SIZE Wide Flange Beam / 12 X 26# / 310 X 38.7	DOCUMENT ID: 0001015047
SALES ORDER 13459791/000030		CUSTOMER MATERIAL N° 000000003712260040		LENGTH 40'00"	PCS 12	WEIGHT 12,480 LB
CUSTOMER PURCHASE ORDER NUMBER 4500561404		BILL OF LADING 1327-0000551832		DATE 10/20/2023		
SPECIFICATION / DATE or REVISION ASTM A6-17 ASTM A709-21 GR50 ASTM A992-20, A572-21 CSA G40.21-13 345WM, 50W						

CHEMICAL COMPOSITION												
C (%)	Mn (%)	P (%)	S (%)	Si (%)	Cu (%)	Ni (%)	Cr (%)	Mo (%)	Sn (%)	V (%)	Nb (%)	CEqvA6 (%)
0.09	0.89	0.010	0.026	0.17	0.32	0.11	0.14	0.023	0.011	0.002	0.018	0.30

MECHANICAL PROPERTIES		UTS (PSI)	YS (MPa)	UTS (MPa)	Y/T rati (%)	G/L (Inches)	G/L (mm)	Elong. (%)
YS 0.2% (PSI)		68337	390	471	0.830	8.000	200.0	23.30
56538		66069	380	456	0.830	8.000	200.0	23.50
55052								

COMMENTS / NOTES

Gerdaus steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdaus possession. For all products other than billets or beam blanks, this material was produced (Electric Arc Furnace, Melted, Continuously Cast, Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was produced (Electric Arc Furnace, Melted and Continuously Cast) in the USA. CMTR complies with EN 10204 3.1.

Bhaskar
BHASKAR YALAMANCHILI
QUALITY DIRECTOR
Phone: (409) 267-1071 Email: Bhaskar.Yalamanchili@gerdau.com

Wade A. Lumpkins
WADE LUMPKINS
QUALITY ASSURANCE MGR.
Phone: 972-779-3118 Email: Wade.Lumpkins@gerdau.com