

Ship From:
2000 Independence Ave NW
Decatur, AL 35601
USA

MTR No: TC0000010669
MTR Date: 11/8/2023

| | | |
|--------------------------|--------------------------------|--------------------------------|
| Nucor Item No: | 102134 | Product Description |
| Description: | 8" X 8" X 1/4" A500 20' (240") | 8" X 8" X 1/4" A500 20' (240") |
| Customer PO No/ Line No: | 4500560925/ | |
| Customer Part No: | | |
| Third party PO number: | | |
| Nucor SO No/ Line No: | 174555/2 | |
| BOL No: | BL0000003358 | |
| Nucor Load No: | LD0000005685 | |
| Heat No: | AA9831 | |
| Quantity Shipped: | (1) PC | |
| Bundles: | 1 | |
| Furnace Batch No: | | |

MTR Notes:

THIS MATERIAL MEETS A500 B/C GRADE

Chemical:

| | | |
|-------------|---------------------|-----------|
| Al = 0.039 | B = 0.0002 | C = 0.2 |
| Ca = 0.0017 | CARBON EQ. = 0.3054 | Cr = 0.07 |
| Cu = 0.12 | Mn = 0.47 | Mo = 0.01 |
| N = 0.0075 | Nb = 0.00 | Ni = 0.04 |
| P = 0.01 | S = 0.001 | Si = 0.03 |
| Sn = 0.004 | Ti = 0.001 | V = 0.002 |

Mechanical:

| | | |
|---------------|-----------------|-------------------|
| YIELD = 55300 | TENSILE = 75600 | ELONGATION % = 34 |
|---------------|-----------------|-------------------|

Physical:

No weld repair was performed on this product at the location indicated on this certification
Mercury in any form has not been used in the production or testing of this material
This document is in compliance with EN 10204 "type 3.1"
NDT equipment calibrated by OEM



Nora Oukajji
Quality Supervisor

I certify that the above figures are a true and correct copy of those contained in the records of this company.