

Sold By:
NUCOR TUBULAR PRODUCTS INC.
DECATUR DIVISION
2000 INDEPENDENCE AVENUE N.W.
DECATUR, AL 35601
Tel: 256 306-6200
Fax: 256 340-7415

Purchase Order No: 4500556997
Sales Order No: DCR 171609 - 2
Bill of Lading No: DCR 123353 - 5
Invoice No:

Shipped: 8/15/2023
Invoiced:

Sold To:
4750 W. MARSHALL AVENUE
LONGVIEW, TX 75604

Ship To:
4750 W. MARSHALL AVENUE
LONGVIEW, TX 75604

CERTIFICATE of ANALYSIS and TESTS

Certificate No: DCR 45684

Customer Part No:

Test Date: 8/11/2023

TUBING A500 GRADE B(C)
12" X 8" X 1/4" X 40'

Total Pieces Total Weight Lbs
4 5,221

Bundle Tag	Mill	Heat	Specs	Y/T Ratio	Pieces	Weight Lbs
251773	40N	NN3475	YLD=59700/TEN=74700/ELG=34	0.7992	4	5,221

Mill #: 40N Heat #: NN3475 Carbon Eq: 0.2899 Heat Src Origin: MELTED AND MANUFACTURED IN THE USA

C	Mn	P	S	Si	Al	Cu	Cr	Mo	V	Ni	Nb	Cb
0.2000	0.3900	0.0060	0.0000	0.0410	0.0370	0.1300	0.0600	0.0100	0.0010	0.0300	0.0060	0.0060

Sn	N	B	Ti	Ca
0.0020	0.0068	0.0003	0.0020	0.0012

Certification:

I certify that the above results are a true and correct copy of records prepared and maintained by NUCOR TUBULAR PRODUCTS, INC. Sworn this day, 8/11/2023.

THE SPECIFICATIONS LISTED BELOW REPRESENT THE CURRENT ISSUED DATES OF THESE STANDARDS. THIS DOES NOT INDICATE THAT THE MATERIAL ABOVE CONFORMS TO EACH OR ALL OF THE STANDARDS. WE CERTIFY THE MATERIAL ABOVE TO THE SPECIFICATION LISTED IN THE LINE DESCRIPTION.

CURRENT STANDARDS:

- A252-19
- A500/A500M-21
- A513/A513M-21
- ASTM A53/A53M-20 | ASME SA-53/SA-53M-21
- A847/A847M-14
- A1085/A1085M-15
- IN COMPLIANCE WITH EN 10204 SECTION 4.1
- INSPECTION CERTIFICATE TYPE 3.1



Nora Oukajji
Metallurgist/Quality Supervisor