



# Certified Inspection Report

Taber Extrusions, LLC  
1900 34th Street  
Gulfport, MS 39501

Sales Order #

42685/1-1

Customer # Customer PO#

00500-0

607297

Melted and Manufactured  
in the United States

S O I D T O P O BOX 3484  LAFAYETTE, LA 70502  USA	S H I P T O EAST 101 THRUWAY PK  BROUSSARD, LA 70518  USA
--	---

Item	Die Number	Part Description	Alloy - Temper	Length	Pieces	Pounds
1	01355	2 X 2 X .25 ANGLE 2259	6061 - T6	300	282	7826

### Chemical Composition Limits

Specification(s): ASTMB221-21 & AMS QQ-A-200/8

Alloy: 6061	Total														
	Al	Si	Fe	Cu	Mn	Mg	Cr	Zn	Ga	V	Ti	B	Zr	Each	Total
Min		0.40		0.15		0.80	0.04								
Max		0.80	0.70	0.40	0.15	1.20	0.35	0.25			0.15			0.05	0.15

SampleID	UTS	TYS	ELONG	Heat	Drop	Si	Fe	Cu	Mn	Mg	Cr	Zn	Ti
42685-1-1-1	41.7	35.2	10	46067	2	.69	.20	.24	.11	.98	.08	.01	.01
42685-1-1-2	42.5	35.3	10										
42685-1-1-3	41.5	35.6	12										
42685-1-1-4	42.2	35.9	13										
42685-1-1-5	41.7	35.4	12										
42685-1-1-6	42.2	36.8	14										
42685-1-1-7	40.4	35.4	14										
42685-1-1-8	40.9	35.7	13										

### Certificate of Inspection and Test Results

The undersigned certifies that the material, processes, and testing used in the fabrication of this order meet all applicable specifications in the item description. Unless the item description indicates otherwise, the current Aluminum Association Standards and the Data Publication is considered the applicable reference. Test reports showing compliance to the appropriate specifications are on file subject to examination.

This certification shall be deemed a part of and subject to all of the terms and conditions set forth on the front and reverse sides of Taber Extrusions Gulfport's Quotation and/or Order Acknowledgement Form.

TABER EXTRUSIONS GULFPORT

By:

Monday, November 20, 2023

Page 1