



A DIVISION OF ZEKELMAN INDUSTRIES

REF.B/L: 81195581  
Date: 01/17/2024  
Customer: 179

Atlas Tube Arkansas  
6651 E Hwy 137  
Blytheville Arkansas USA  
72315

Tel:  
Fax:

**MATERIAL TEST REPORT**

Shipped To

Wiersnall Avenue  
LONGVIEW TX 75604  
USA

Sold To

MANHATTAN KS 66505  
USA

Material: 6.0x6.0x188x40"0"(3x3).  
Material No: 600601884000  
Purchase Order: C452006613  
Sales Order: 1997238  
Heat No: 23170651  
Bundle No: M500494801  
Heat: 23170651  
MILL: BIGRIVER  
Yield: 058967 Psi  
Tensile: 077356 Psi  
Eln.2in: 34 %  
Method: EAF  
Recycled Content: 76.00%  
Post Consumer: 95.00%  
Pre-Consumer: 5.00 %  
Certification: ASTM A500-21 GRADE B&C  
Within Miles of Location: 500  
CE: 0.36

Material	V	Ti	B	N	Ca
23170651	0.003	0.002	0.0002	0.0075	0.0029

Made in: USA  
Melted and Poured in: USA  
Cust Material#: 6560018840

Material Note:  
Sales Or. Note:

Material: 8.0x6.0x250x40"0"(3x2).  
Material No: 800602504000  
Purchase Order: C452006600  
Sales Order: 1995133  
Heat No: 23182051  
Bundle No: M500496388  
Heat: 23182051  
MILL: BIGRIVER  
Yield: 059802 Psi  
Tensile: 076948 Psi  
Eln.2in: 35 %  
Method: EAF  
Recycled Content: 76.00%  
Post Consumer: 95.00%  
Pre-Consumer: 5.00 %  
Certification: ASTM A500-23 GRADE B&C  
Within Miles of Location: 500  
CE: 0.35

Material	V	Ti	B	N	Ca
23182051	0.004	0.001	0.0002	0.0079	0.0027

Made in: USA  
Melted and Poured in: USA  
Cust Material#: 6680060025040

Material Note:  
Sales Or. Note:

Authorized by Quality Assurance *Jason Richard*  
**Jason Richard**

The results reported on this report represent the actual attributes of the material furnished and indicate full compliance with all applicable specification and contract requirements. CE calculated using the AWS D1.1 method. Steel is purchased fully killed with a fine grain practice. This document is in compliance with the requirements of EN10204 type 3.1

