CERTIFIED MATERIAL TEST REPORT

GERDAU

US-ML-MIDLOTHIAN
300 WARD ROAD
MIDLOTHIAN, TX 76065
USA

CUSTOMER SHIP TO	CUSTOMER BILL TO
STEEL AND PIPE SUPPLY CO INC 4750 W MARSHALL AVE LONGVIEW,TX 75604-4817 USA	STEEL AND PIPE SUPPLY CO INC MANHATTAN,KS 66505-1688 USA

GRADE	SHAPE / SIZE	DOCUMENT ID:
A992/A572-50	Wide Flange Beam / 10 X 49# / 250 X 73	0001055519

LENGTH	PCS	WEIGHT	HEAT / BATCH
20' 00"	8	7,840 LB	**59115315**/07

SALES ORDER	CUSTOMER MATERIAL Nº
13556433/000010	000000003710490020

SPECIFICATION / DATE or REVISION
ASTM A6-17
ASTM A709-21 GR50
ASTM A992-20, A572-21
CSA G40.21-13 345WM, 50W

CUSTOMER PURCHASE ORDER NUMBER	BILL OF LADING	DATE
4500563816	1327-0000564318	01/29/2024

CHEMICAL COMPOSITION

C (%)	Mn (%)	P (%)	S (%)	Si (%)	Cu (%)	Ni (%)	Cr (%)	Mo(%)	Sn (%)	V (%)	Nb (%)	CEqvA6 (%)
0.09	0.85	0.013	0.024	0.21	0.18	0.05	0.20	0.016	0.003	0.001	0.021	0.29

MECHANICAL PROPERTIES

YS 0.2% (PSI)	UTS (PSI)	YS (MPa)	UTS (MPa)	Y/T rati (%)	G/L (Inches)	G/L (mm)	Elong. (%)
54371	70915	375	489	0.770	8.000	200.0	24.20
53204	68890	367	475	0.770	8.000	200.0	24.00

COMMENTS / NOTES

Gerdau's steel is 100% recyclable. Support the circular economy through our Metals Recycling Partnership. For details, visit www2.gerdau.com/metals-recycling, or contact metalsrecycling@gerdau.com.

The above figures are certified chemical and physical test records as contained in the permanent records of the company. We certify that these data are correct and in compliance with specified requirements. No weld repair was performed on this material. The material has not been in contact with mercury while in Gerdau possession. For all products other than billets or beam blanks, this material was produced (Electric Arc Furnace, Melted, Continuously Cast, Hot Rolled and, if applicable, Cold-Drawn) in the USA. For billets or beam blanks, this material was produced (Electric Arc Furnace, Melted and Continuously Cast) in the USA. CMTR complies with EN 10204 3.1.

BHASKAR YALAMANCHILI
QUALITY DIRECTOR
Phone: (409) 267-1071 Email: Bhaskar.Yalamanchili@gerdau.com

WADE LUMPKINS
QUALITY ASSURANCE MGR.
Phone: 972-779-3118 Email: Wade.Lumpkins@gerdau.com